

ENGINE TEST [CTG00540]

(CTG00540)-ENGINE (AEZ00372)-GENERATOR (FDX00474)-
GENSET

MARCH 21, 2024

For Help Desk Phone Numbers Click here

Help

Sales Model: 3516B
TMI Load Date: 20Dec2007
Built Date: 19Dec2007
Shipped Date: 17Jan2008
Plant: Lafayette

Tested Date: 20Dec2007
Tested: B
Cell Number: 505

Show **50** entries

Search:

Test Element	Eng Updates	Test Value	Test Spec Value	Measure
Spec Number		0K3250	0K3250	
Arrangement Number		2050345	2050345	
Corr FI Power		2,189.4	2,190.0	KW
Speed		1,499	1,500	RPM
COR FL FUEL RATE		7,295.4	7,265.0	G/MIN
CSFC		199.9	199.0	G/KW-HR
Adj Boost		260.3	256.0	KPA
Fuel Pressure		390	354	KPA
Oil Pressure		371	360	KPA
TQ COR FUEL RATE		0.0		G/MIN
TQ CK COR TQ		0		NM
Low Idle Speed		901	900	RPM
Low Idle Oil Pressure		353	347	KPA
High Idle Speed		1,516	1,515	RPM
FL Static Fuel Setting		29.6	29.6	MM
FT Static Fuel Setting		29.6	29.6	MM
FLS (INTRCPT)	0			
FTS (SLOPE)	0			

Showing 1 to 18 of 18 entries

Previous **1** Next

	Value	Unit
Advertised Power	2,145.0	KW
Advertised Speed	1,500	RPM

Caterpillar Confidential: **Green**
Content Owner: Commercial Processes Division
Web Master(s): PSG Web Based Systems Support
Current Date: 3/21/2024, 2:04:40 PM
© Caterpillar Inc. 2024 All Rights Reserved.
Data Privacy Statement.
[Cookie Settings](#)